



## ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with Belgian requirements for gas press fittings.  
*Le laboratoire de l'ARGB certifie que les raccords à sertir gaz sont conformes aux exigences Belges.*  
 Het laboratorium van de KVBG verklaart dat de gas persfittings conform zijn aan de Belgische eisen.

Certificate Number : **C-16-3742-A**  
 N° du certificat :  
 Certificaat nummer :

Date of issue : **16/12/2016**  
 Date d'édition :  
 Datum van aflevering :

Manufacturer : **Raccorderie Metalliche S.p.A.**  
 Fabricant : **Strada Sabbionetana, 59**  
 Fabrikant : **IT-46010 Campitello di Marcaria (MN)**  
**ITALY**

Distributor : **Raccorderie Metalliche S.p.A.**  
 Distributeur :  
 Verdelers :

Type: **AESPRES Gas (with O-ring NBR)**  
 Copper & Copper alloys gas press fittings for copper tubes pipes  
 (according to EN 1057)  
*Raccords à sertir en cuivre et alliages de cuivre pour tuyaux en cuivre (conforme à la EN 1057)*  
 Koper & Koperlegering gas persfittings voor koperen buizen  
 (volgens EN 1057)

**MOP: 5 bar - GT: 1 bar**  
**Diameter: 15 – 18 – 22 – 28 -35 – 42 – 54 mm**

ART. 681/450 G Elbow 45° FF  
 ART. 681/451 G Elbow 45° MF  
 ART. 681/900 G Elbow 90° FF  
 ART. 681/901 G Elbow 90° MF  
 ART. 697 G Elbow adapter 90° M thread  
 ART. 698 G Elbow adapter 90° F thread  
 ART. 682 G Equal Tee F  
 ART. 689 G Branch Tee F BSP outlet  
 ART. 692 G Reducing Tee  
 ART. 683/003 G Stop End  
 ART. 683/000 G Coupling  
 ART. 683/001 G Slip Coupling  
 ART. 687 G Male Adapter  
 ART. 690 G Female Adapter  
 ART. 691 G Reducer MF  
 ART. 685 G Wall Plate Elbow 90°

Scope : **■ Low and medium pressure gas installations according to the standards**  
*Domaine d'application :* **NBN D51-003 and NBN D51-004**  
*Toepassingsgebied :* **■ Installations basse et moyenne pression suivant les normes NBN D51-003 et NBN D51-004**  
**■ Lage en midden druk gasinstallaties volgens de normen NBN D51-003 en NBN D51-004**

Requirements: **DVGW Certificate – nr. DG-8531CL0376 (03.02.2015)**  
*Exigences :* **TTR Institute - nr. 20141224 (24/12/2014)**  
*Eisen :* **NBN P12-001 "Copper and copper alloys – Fitting for sanitary, heating and gas installations – Fittings with press ends for metallic tubes"**

  
 Olivier THIBAUT, Laboratory Manager